

Schena, Cristeen

From: Aram Varjabedian <avarjabedian@woodardcurran.com>
Sent: Wednesday, April 25, 2018 4:30 PM
To: tberardinelli@town.hull.ma.us; Bill Boornazian; david.burns (david.burns@state.ma.us); Jim Dow; Frank Cavaleri; jstruzziery@town.hull.ma.us; jsullivan (jsullivan@town.hull.ma.us); kbornheim (kbornheim@town.hull.ma.us); Krahforst, Chris (ckrahforst@town.hull.ma.us); Lemnios, Philip (plemnios@town.hull.ma.us); coconnor@town.hull.ma.us; Robert Scott; Turin, David; Joyce, Ryan (FWE) (ryan.joyce@state.ma.us)
Subject: RE: 24 Meade Ave SSO - Hull, MA - MA0101231 - SSO Report for 4/20/18
Attachments: SSO_Notification_report_rev2_042518_for042018_24_MeadeAve.pdf

Good Afternoon:

Please find the attached SSO report for the 24 Meade Ave incident that occurred on 4/20/18. Should you need any additional information, please let me know.

Sincerely,

Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS

From: Aram Varjabedian
Sent: Friday, April 20, 2018 5:31 PM
To: Aram Varjabedian ; Berardinelli, Terri ; Bill Boornazian ; david.burns (david.burns@state.ma.us) ; Dow, James (jdow@town.hull.ma.us) ; Frank Cavaleri ; jstruzziery (jstruzziery@town.hull.ma.us) ; jsullivan (jsullivan@town.hull.ma.us) ; Kate Roosa (kroosa@woodardcurran.com); kbornheim (kbornheim@town.hull.ma.us) ; Krahforst, Chris (ckrahforst@town.hull.ma.us) ; Lemnios, Philip (plemnios@town.hull.ma.us) ; O'Connor, Carol ; Robert Scott (rscott@woodardcurran.com) ; Turin, David (Turin.David@epa.gov) ; Joyce, Ryan (FWE) (ryan.joyce@state.ma.us)
Subject: 24 Meade Ave SSO - Hull, MA - MA0101231 - Preliminary notification

Good afternoon:

I am emailing to inform you that a very small SSO occurred this morning as a result of a clogged gravity sewer line at 24 Meade Ave. The leak was reported to the Sewer Dept by Jim Dow, of the Hull DPW at approximately 8:30am. W&C staff responded immediately to investigate the issue. Outside assistance was needed as the source of the leak was a surcharged manhole, with very little flow getting through.

While waiting for the sewer jet/vac truck, the leakage stopped at 9:15am. A call had already been made to JHoadley for vector truck and sewer jetter assistance, and they were on their way. The service truck arrived by 10:20am, and the line clog was cleared, and area washed down. Approximately 173 ft of sewer line was jetted.

Dye testing and additional manhole inspections were conducted. No sewage made it to any catch basins, as there were none in area.

Estimated leakage at less than 20 gallons.

Should you need additional information, please don't hesitate to contact me. A full SSO report will be made within the next 2-3 days.

Sincerely,

Aram

Aram Varjabedian

Plant Manager

Hull Wastewater Treatment Facility

1111 Nantasket Avenue | Hull, MA 02045

Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334

www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS